



STEVE TSHWETE LOCAL MUNICIPALITY

Telephone (013) 2497000

Fax (013) 2432550

Your ref.

Our ref. cjr/rm 16/3/1

30/09/2016

P O Box 14
MIDDELBURG, MPUMALANGA

1050

www.stlm.gov.za

E-Mail : council@stlm.gov.za

The Applicant

MIDDELBURG

1050

Dear Sir / Madam

**APPLICATION FOR THE DRILLING OF A BOREHOLE: ERF
MIDDELBURG EXTENSION**

With reference to your application dated _____ 2016 to drill a borehole on the above erf has been approved subject to the following conditions:

1. Water that is withdrawn from the borehole may only be used for the watering of plants and it may not be connected to the municipal water network or allowed that any of the water enters the municipal sewer network.
2. The Municipality will not be responsible for any costs if a restriction should be placed on the use of water from boreholes.
3. A pump house, when placed over the pump, may not be nearer than 3 metres from the side boundaries of the stand, and may also not exceed the applicable building lines.
4. Drilling will only be allowed between the hours of 6:00 and 18:00.
5. The applicant will be held responsible for any damages caused to a property or any accidents that may occur due to the drilling activities.

6. As soon as the work has been completed, the applicant should submit the following information to the office of the Assistant Director Water Services in the Infrastructure Building situated in SADC Street:
 - Borehole name (Street address).
 - GPS Coordinates.
 - Depth.
 - Latest water level.
 - Yield
 - Equipment.
 - Borehole rest data.
 - Borehole construction logs
 - The status of the borehole.
7. The relevant information will be captured in a National data base, which will be made available to the Department of Water & Sanitation.
8. Should an emergency draught situation occur the Council shall have the right to utilise water from the borehole and treat the water to a potable standard.
9. The proposed drilling exercise must comply with all other Standard Building Regulations requirements, the National Water Act, the Water Service Act and the Water Services By-Laws.
10. The Applicant / Property owner will be held responsible for any damages caused to any Municipal or private infrastructure.
11. The Applicant / Property owner shall, upon completion, submit a site plan on a scale of 1: 500 which indicates the exact location of the borehole on the property / erf.
12. A noticeboard indicating the existence of a borehole must be placed on a visible place in front of the property in question.

For any further information please contact the Water Services Department, Mr Victor Sambo at 013-249 7258.

Yours faithfully

S.M.MNGUNI
ACTING MUNICIPAL MANAGER

COPIES: TPS SECRETARY
RECORDS DEPARTMENT